



NOTES:

1. GATE VALVES SHALL OPEN CCW AND BE RESILIENT SEAT MEETING REQUIREMENTS OF AWWA C509.
2. FITTINGS SHALL BE WRAPPED WITH 8 MIL MINIMUM THICKNESS POLYETHYLENE SHEETING.
3. VALVE BOX TOP SHALL BE SET 1/2" BELOW FINAL ASPHALT PAVEMENT GRADE.
4. PROVIDE MARKER POST WHERE NECESSARY.



STANDARDS &  
SPECIFICATIONS

REVISED:

## VALVE BOX DETAIL

DATE:

DRAWING NO. 200-38